

**SAS Superstructure**

Location: 04-SF-80-13.2 / 13.9

Client Name: CalTrans

Run date 21-Nov-14

Time 10:51 PM

Daily Diary Report by Bid Item

Contract No.: 04-0120F4

Diary #: 742 Const Calendar Day: 197 Date: 18-Dec-2012 Tuesday

Inspector Name: Bruce, Matt Title: Transportation Engineer

Inspection Type: Intermittent

Shift Hours: 07:00 am 03:30 pm Break: 00:30 Over Time:

Federal ID:

Location:

Reviewer: Schmitt, Alex

Approved Date:

Status: Submit

**04-0120F4
04-SF-80-13.2/13.9
Self-Anchored
Suspension Bridge****Weather****Temperature** 7 AM 40 - 50 12 PM 50 - 60 4PM 50 - 60**Precipitation** 0.00"**Condition** Mostly overcastWorking Day ☐ If no, explain:**Diary:**

Dispute

Work description.

- Intermittently checked if ABF ironworker crews were working on the messenger and handrope cables. Informed ABF engineer Ankur Singh that the handrope bolts need to be tested where the 48hr requirement has already passed.
- Inspected the grouting done on the short vertical PT bars embedded in the W2 cap beam.
- Wrote outstanding diaries from last week.
- Continued to review documents related to the handrope and messenger cables.

